

Prepared to OSHA, ACC, ANSI, NOHSC, WHMIS, 2001/58 & 1272/2008/EC Standards SDS Revision: 1. Revision Date: 10/24/2016

1.1	Product Name:	Kenra Air Grip Spray 9
	Chemical Name:	Aerosol
1.3	Synonyms:	Dry Matte Wax – 55% VOC
1.4	Trade Names:	Kenra Air Grip Spray 9
15 I	Product Uses & Restrictions	Professional and Cosmetic Use
1.6	Distributor's Name:	KIK Custom Products
1.7	Distributor's Address:	2730 Middlebury Street, Elkhart, IN 46515 USA
1.8	Emergency Phone:	Poison Control Center (Medical): (866) 366-5048; CHEMTREC: +1 (800) 424-9300 /+1 (703)527-3887
1.9	Business Phone / Fax:	+1 (574) 295-0000 / +1 (574) 295-1709

2. HAZARDS IDENTIFICATION

Hazard Identification: This product is classified as a HAZARDOUS SUBSTANCE and as DANGEROUS GOODS according to the classification criteria of NOHSC: 1088 (2004) and ADG Code (Australia)

> WARNING! FLAMMABLE AEROSOL. PRESSURIZED CONTAINER: MAY BURST IF HEATED. HIGHLY FLAMMABLE LIQUID AND VAPOR. CAUSES EYE IRRITATION.

Classification: Aerosol level 2; Category 2 Flammable aerosol; Eye Irrit. 2

Hazard Statements (H): H-223 - Flammable Aerosol. H229 - Pressurized container: may burst if heated. H320 - Causes eye irritation.

Precautionary Statement (P):

P210 – Keep away from heat, hot surfaces, sparks, open flames and other ignition sources. No Smoking; P211 - Do not spray on an open flame or other ignition source; P251 - Do not pierce or burn, even after use; P261 – avoid breathing vapors/spray; P271 – Use only in well-ventilated area; P304+P340 – IF INHALED; Remove person to fresh air and keep comfortable for breathing; P305+P351+338 - IF INEYES; Rinse cautiously with water for several minutes. Remove contact lenses, if present, continue rinsing; P337+P313 – If eye irritation persists: Get medical advice/attention; P410+P412 - Protect from sunlight. Do no expose to temperature exceeding 48°C (120°F); P501 -Dispose of contents/container to licensed and permitted disposal or recycling facility.



3. COMPOSITION & INGREDIENT INFORMATION						
Substance / Chemical Name(s)	CAS No.	EINECS No.	%	Other		
Dimethyl Ether	115-10-6	204-065-8	40 - 60	Press. Gas 1; Flam. Gas 1; H220		

Dillik	ettiyi Ettiei	113-10-0	204-003-6 40 - 00 F1ess. Gas 1, Halli. Gas 1, HZ20
			4. FIRST AID MEASURES
4.1	First Aid:	Ingestion:	If ingested, do not induce vomiting! If product has been swallowed, drink plenty of water or milk IMMEDIATELY. If the patient is vomiting, continue to offer water or milk. Never give water or milk to an unconscious person. Contact the nearest Poison Control Center or local emergency number. Provide an estimate of the time at which the material was ingested and the amount of the substance that was swallowed.
		<u>Skin:</u>	If irritation occurs & product is on the skin, rinse thoroughly with lukewarm water, followed by a thorough washing of the affected area with plenty of soap and water. Remove contaminated clothing and wash thoroughly before ruse. If irritation, redness or swelling persists, consult a physician immediately.
		Eyes:	If product get in the eyes, flush with copious amounts of lukewarm water for at least 15 minutes. Raise and lower eyelid(s) while flushing to ensure thorough irrigation. If problems persist, seek immediate medical attention.
		Inhalation:	Remove victim to fresh air and keep comfortable for breathing.
4.2	Effects of Exposure:	Ingestion:	If product is swallowed, may cause nausea, vomiting and/or diarrhea and central nervous system depression.
		Skin:	May be irritating to skin. The product can cause allergic skin reactions (e.g., rashes, welts, dermatitis) in some sensitive individuals upon prolonged or repeated exposure.
		Eyes:	Moderately irritating to the eyes.

B-9818 H

_							
	Prepared to OSHA, AC	C, ANSI, NOHSC,	WHMIS, 2001/58 & 1272/2008/EC Standards	SDS Revision: 1. Revision Date: 10/24	•		
			Vapors of this product may be moderately irritati				
		Inhalation: respiratory system. Symptoms of overexposure can include coughing, wheezing, nasal congestion					
		illialation.	and difficulty breathing. Inhalation of concentrat	ed vapors can cause nervous syster	n depression		
			(e.g., drowsiness, dizziness, headaches, nausea).				
4.3	Symptoms of Overexposure	Ingestion:	May cause nausea, vomiting and/or diarrhea and	central nervous system depression			
			Prolonged contact with skin may result in bleachi				
		Skin:	allergic skin reactions (e.g., rashes, welts, dermat	-			
			overexposure may include redness, itching, and in		, ,		
			Overexposure in eyes, may cause redness, itching		ge to eves)		
		Eyes:	Contact may cause mild eye irritation including st		8,,		
			Symptoms of overexposure can include coughing		fficulty		
		Inhalation:	breathing.	, wheeling, hasar congestion, and a	incurcy		
		Moderate irrit	ation to eyes and skin near affected areas. Addition	ally high concentrations of vanors	ran calise		
4.4	Acute Health Effects:		zziness, headaches and nausea.	any, mgn concentrations of vapors	an cause		
			chronic health effects are expected to occur from a	single accidental ingestion. These i	ngredients n		
			skin and mucous membrane of the eye and respirat		-		
4.5	Chronic Health Effects:		ome sensitive individuals. May also induce skin sens				
		allergic derma		sicization and respiratory hypersens	icivity. PUSSI		
16	Target Organs:						
4.6 4.7	Target Organs: Medical Conditions		piratory system. Tazards may be delayed. Most common symptoms	HEALTH	1		
4.7	Aggravated by Exposure		ng properties to eyes, respiratory system and skin.	FLAMMABILITY	3		
	Aggravated by Exposure		atological conditions (such as eczema) and				
		-	nditions (such as bronchial asthma and/or	PHYSICAL HAZARDS	0		
		i respiratory coi	· ·	PROTECTIVE EQUIPMENT	В		
		branchitic) ma	v ha avacarbatad				
5.1	Fire and Explosion Hazards:	Level 2 Aeroso	5. FIREFIGHTING MEASURES of (NFPA 30B). Aerosols may burst at temperatures and talents to prevent possible bursting. Aerosols may	above 120° F (48°C). Cool be projectile hazards when			
5.1	·	Level 2 Aeroso uninvolved con bursting. If ae and release fla containers coo	5. FIREFIGHTING MEASURES of (NFPA 30B). Aerosols may burst at temperatures antainers to prevent possible bursting. Aerosols may rosols are bursting, stay clear until bursting is complementable liquids and/or exposed gases if exposed to be by spraying them with water until the fire has been	above 120° F (48°C). Cool be projectile hazards when lete. Containers may rupture the heat of fire. Keep	3		
5.2	Extinguishing Methods:	Level 2 Aeroso uninvolved con bursting. If ae and release fla containers coo Water Fog, Fos	5. FIREFIGHTING MEASURES of (NFPA 30B). Aerosols may burst at temperatures a ntainers to prevent possible bursting. Aerosols may rosols are bursting, stay clear until bursting is complemmable liquids and/or exposed gases if exposed to old by spraying them with water until the fire has been am, CO ₂ , Dry Chemical	above 120° F (48°C). Cool be projectile hazards when ete. Containers may rupture the heat of fire. Keep n extinguished.	3		
	·	Level 2 Aerosc uninvolved cor bursting. If ae and release fla containers coo Water Fog, Foo As in any fire, v	5. FIREFIGHTING MEASURES of (NFPA 30B). Aerosols may burst at temperatures a ntainers to prevent possible bursting. Aerosols may rosols are bursting, stay clear until bursting is complemmable liquids and/or exposed gases if exposed to old by spraying them with water until the fire has been am, CO ₂ , Dry Chemical wear MSHA/NIOSH approved self-contained breathing.	above 120° F (48°C). Cool be projectile hazards when ete. Containers may rupture the heat of fire. Keep n extinguished. ng apparatus (pressure-	130		
5.2	Extinguishing Methods:	Level 2 Aerosc uninvolved col bursting. If ae and release fla containers coo Water Fog, Foo As in any fire, of demand_ and	5. FIREFIGHTING MEASURES of (NFPA 30B). Aerosols may burst at temperatures a ntainers to prevent possible bursting. Aerosols may rosols are bursting, stay clear until bursting is complemmable liquids and/or exposed gases if exposed to old by spraying them with water until the fire has been am, CO ₂ , Dry Chemical wear MSHA/NIOSH approved self-contained breathifull protective gear. Keep containers cool until well	above 120° F (48°C). Cool be projectile hazards when ete. Containers may rupture the heat of fire. Keep n extinguished. ng apparatus (pressure- after the fire is out. Use water	130		
5.2	Extinguishing Methods:	Level 2 Aerosc uninvolved col bursting. If ae and release fla containers coc Water Fog, Fod As in any fire, v demand_ and spray to cool f	5. FIREFIGHTING MEASURES of (NFPA 30B). Aerosols may burst at temperatures a intainers to prevent possible bursting. Aerosols may rosols are bursting, stay clear until bursting is compl immable liquids and/or exposed gases if exposed to of by spraying them with water until the fire has been am, CO ₂ , Dry Chemical wear MSHA/NIOSH approved self-contained breathi full protective gear. Keep containers cool until well ire-exposed surfaces and to protect personnel. Figh	above 120° F (48°C). Cool be projectile hazards when ete. Containers may rupture the heat of fire. Keep n extinguished. ng apparatus (pressure- after the fire is out. Use water t fire upwind. Prevent runoff	130		
5.2	Extinguishing Methods:	Level 2 Aerosc uninvolved cor bursting. If ae and release fla containers coo Water Fog, Fog As in any fire, of demand_ and spray to cool f from fire contri	5. FIREFIGHTING MEASURES of (NFPA 30B). Aerosols may burst at temperatures a ntainers to prevent possible bursting. Aerosols may rosols are bursting, stay clear until bursting is complementable liquids and/or exposed gases if exposed to obly spraying them with water until the fire has been am, CO ₂ , Dry Chemical wear MSHA/NIOSH approved self-contained breathifull protective gear. Keep containers cool until well ire-exposed surfaces and to protect personnel. Fighrol or dilution from entering sewers, drains, drinking	above 120° F (48°C). Cool be projectile hazards when ete. Containers may rupture the heat of fire. Keep n extinguished. ng apparatus (pressure- after the fire is out. Use water t fire upwind. Prevent runoff water supply, or any natural	130		
5.2	Extinguishing Methods:	Level 2 Aerosc uninvolved con bursting. If ae and release fla containers coo Water Fog, Foo As in any fire, demand_ and spray to cool f from fire contr waterway. Fir	5. FIREFIGHTING MEASURES of (NFPA 30B). Aerosols may burst at temperatures a ntainers to prevent possible bursting. Aerosols may rosols are bursting, stay clear until bursting is complementable liquids and/or exposed gases if exposed to be by spraying them with water until the fire has been am, CO ₂ , Dry Chemical wear MSHA/NIOSH approved self-contained breathifull protective gear. Keep containers cool until well ire-exposed surfaces and to protect personnel. Fighrol or dilution from entering sewers, drains, drinking efighters must use full bunker gear including NIOSH-	above 120° F (48°C). Cool be projectile hazards when ete. Containers may rupture the heat of fire. Keep n extinguished. ng apparatus (pressure- after the fire is out. Use water t fire upwind. Prevent runoff water supply, or any natural -approved positive pressure self-	130		
5.2	Extinguishing Methods:	Level 2 Aerosc uninvolved con bursting. If ae and release fla containers coo Water Fog, Foo As in any fire, demand_ and spray to cool f from fire contr waterway. Fir contained brea	5. FIREFIGHTING MEASURES of (NFPA 30B). Aerosols may burst at temperatures a ntainers to prevent possible bursting. Aerosols may rosols are bursting, stay clear until bursting is complemental liquids and/or exposed gases if exposed to blood by spraying them with water until the fire has been am, CO ₂ , Dry Chemical wear MSHA/NIOSH approved self-contained breathing full protective gear. Keep containers cool until well ire-exposed surfaces and to protect personnel. Fighrol or dilution from entering sewers, drains, drinking efighters must use full bunker gear including NIOSH-athing apparatus to protect against potential hazard	above 120° F (48°C). Cool be projectile hazards when ete. Containers may rupture the heat of fire. Keep n extinguished. ng apparatus (pressure- after the fire is out. Use water t fire upwind. Prevent runoff water supply, or any natural -approved positive pressure self-	130		
5.2	Extinguishing Methods:	Level 2 Aerosc uninvolved con bursting. If ae and release fla containers coo Water Fog, Foo As in any fire, demand_ and spray to cool f from fire contr waterway. Fir contained brea	5. FIREFIGHTING MEASURES of (NFPA 30B). Aerosols may burst at temperatures a ntainers to prevent possible bursting. Aerosols may rosols are bursting, stay clear until bursting is complementable liquids and/or exposed gases if exposed to be by spraying them with water until the fire has been am, CO ₂ , Dry Chemical wear MSHA/NIOSH approved self-contained breathifull protective gear. Keep containers cool until well ire-exposed surfaces and to protect personnel. Fighrol or dilution from entering sewers, drains, drinking efighters must use full bunker gear including NIOSH-	above 120° F (48°C). Cool be projectile hazards when ete. Containers may rupture the heat of fire. Keep n extinguished. ng apparatus (pressure- after the fire is out. Use water t fire upwind. Prevent runoff water supply, or any natural -approved positive pressure self-	130		
5.2	Extinguishing Methods:	Level 2 Aeroso uninvolved con bursting. If ae and release fla containers coo Water Fog, Foo As in any fire, of demand_ and spray to cool f from fire contr waterway. Fir contained brea decomposition	5. FIREFIGHTING MEASURES of (NFPA 30B). Aerosols may burst at temperatures a ntainers to prevent possible bursting. Aerosols may rosols are bursting, stay clear until bursting is complemental liquids and/or exposed gases if exposed to blood by spraying them with water until the fire has been am, CO ₂ , Dry Chemical wear MSHA/NIOSH approved self-contained breathing full protective gear. Keep containers cool until well ire-exposed surfaces and to protect personnel. Fighrol or dilution from entering sewers, drains, drinking efighters must use full bunker gear including NIOSH-athing apparatus to protect against potential hazard	above 120° F (48°C). Cool be projectile hazards when ete. Containers may rupture the heat of fire. Keep n extinguished. Ing apparatus (pressure- after the fire is out. Use water t fire upwind. Prevent runoff water supply, or any natural approved positive pressure self- ous combustion or	130		
5.2	Extinguishing Methods:	Level 2 Aerosc uninvolved cor bursting. If ae and release fla containers coo Water Fog, Foo As in any fire, demand_ and spray to cool f from fire contr waterway. Fir contained brea decomposition	5. FIREFIGHTING MEASURES of (NFPA 30B). Aerosols may burst at temperatures a ntainers to prevent possible bursting. Aerosols may rosols are bursting, stay clear until bursting is complete in the interest of the property of the interest of the provided substantial property of the interest of the interest of the provided substantial provided s	above 120° F (48°C). Cool be projectile hazards when ete. Containers may rupture the heat of fire. Keep n extinguished. Ing apparatus (pressure- after the fire is out. Use water t fire upwind. Prevent runoff water supply, or any natural approved positive pressure self- ous combustion or	1 3 CProtective		
5.2	Extinguishing Methods: Firefighting Procedures:	Level 2 Aerosc uninvolved cor bursting. If ae and release fla containers coo Water Fog, Foo As in any fire, demand_ and spray to cool f from fire contr waterway. Fir contained brea decomposition	5. FIREFIGHTING MEASURES of (NFPA 30B). Aerosols may burst at temperatures antainers to prevent possible bursting. Aerosols may rosols are bursting, stay clear until bursting is complementable liquids and/or exposed gases if exposed to be by spraying them with water until the fire has been am, CO ₂ , Dry Chemical wear MSHA/NIOSH approved self-contained breathing full protective gear. Keep containers cool until well irre-exposed surfaces and to protect personnel. Fighrol or dilution from entering sewers, drains, drinking efighters must use full bunker gear including NIOSH-athing apparatus to protect against potential hazard in products and oxygen deficiencies. 6. ACCIDENTIAL RELEASE MEASURES	above 120° F (48°C). Cool be projectile hazards when ete. Containers may rupture the heat of fire. Keep n extinguished. Ing apparatus (pressure- after the fire is out. Use water t fire upwind. Prevent runoff water supply, or any natural approved positive pressure self- ous combustion or	Protective		
5.2	Extinguishing Methods: Firefighting Procedures:	Level 2 Aerosc uninvolved con bursting. If ae and release fla containers coo Water Fog, Foo As in any fire, of demand_ and spray to cool f from fire contri waterway. Fire contained breat decomposition	5. FIREFIGHTING MEASURES of (NFPA 30B). Aerosols may burst at temperatures antainers to prevent possible bursting. Aerosols may rosols are bursting, stay clear until bursting is complementable liquids and/or exposed gases if exposed to be by spraying them with water until the fire has been am, CO ₂ , Dry Chemical wear MSHA/NIOSH approved self-contained breathing full protective gear. Keep containers cool until well irre-exposed surfaces and to protect personnel. Fighrol or dilution from entering sewers, drains, drinking efighters must use full bunker gear including NIOSH-athing apparatus to protect against potential hazard in products and oxygen deficiencies. 6. ACCIDENTIAL RELEASE MEASURES	above 120° F (48°C). Cool be projectile hazards when lete. Containers may rupture the heat of fire. Keep n extinguished. Ing apparatus (pressure- after the fire is out. Use water t fire upwind. Prevent runoff water supply, or any natural approved positive pressure self- ous combustion or			
5.2	Extinguishing Methods: Firefighting Procedures:	Level 2 Aerosc uninvolved conbursting. If ae and release flacontainers coo Water Fog, Fog. As in any fire, demand_ and spray to cool f from fire contravaterway. Fire contained breadecomposition Before cleanin Equipment (PF Small spills Westernster)	5. FIREFIGHTING MEASURES of (NFPA 30B). Aerosols may burst at temperatures a ntainers to prevent possible bursting. Aerosols may rosols are bursting, stay clear until bursting is complementable liquids and/or exposed gases if exposed to be by spraying them with water until the fire has been am, CO ₂ , Dry Chemical wear MSHA/NIOSH approved self-contained breathing full protective gear. Keep containers cool until well ire-exposed surfaces and to protect personnel. Fighrol or dilution from entering sewers, drains, drinking efighters must use full bunker gear including NIOSH-athing apparatus to protect against potential hazard in products and oxygen deficiencies. 6. ACCIDENTIAL RELEASE MEASURES.	above 120° F (48°C). Cool be projectile hazards when lete. Containers may rupture the heat of fire. Keep n extinguished. Ing apparatus (pressure- after the fire is out. Use water t fire upwind. Prevent runoff water supply, or any natural approved positive pressure self- ous combustion or JRES Ip must wear appropriate Personal ding gloves and protective eyewean	. Use a non-		
5.2	Extinguishing Methods: Firefighting Procedures:	Level 2 Aerosc uninvolved corbursting. If ae and release fla containers coo Water Fog, Fog. As in any fire, y demand_ and spray to cool f from fire contravaterway. Fir contained breadecomposition Before cleanin Equipment (PF Small spills We combustible m	5. FIREFIGHTING MEASURES of (NFPA 30B). Aerosols may burst at temperatures antainers to prevent possible bursting. Aerosols may rosols are bursting, stay clear until bursting is complementable liquids and/or exposed gases if exposed to be by spraying them with water until the fire has been am, CO ₂ , Dry Chemical wear MSHA/NIOSH approved self-contained breathing full protective gear. Keep containers cool until well irre-exposed surfaces and to protect personnel. Fighrol or dilution from entering sewers, drains, drinking efighters must use full bunker gear including NIOSH-athing apparatus to protect against potential hazard in products and oxygen deficiencies. 6. ACCIDENTIAL RELEASE MEASURA and spring appropriate personal protective equipment inclusives.	above 120° F (48°C). Cool be projectile hazards when lete. Containers may rupture the heat of fire. Keep n extinguished. Ing apparatus (pressure- after the fire is out. Use water t fire upwind. Prevent runoff water supply, or any natural approved positive pressure self- ous combustion or JRES IP must wear appropriate Personal ding gloves and protective eyewear oduct and place into a container fo	. Use a non- r later dispos		
5.2	Extinguishing Methods: Firefighting Procedures:	Level 2 Aeroso uninvolved con bursting. If ae and release fla containers coo Water Fog, Fog. As in any fire, y demand_ and spray to cool f from fire contravaterway. Fir contained breadecomposition Before cleanin Equipment (PF Small spills We combustible m Do not use wa	5. FIREFIGHTING MEASURES of (NFPA 30B). Aerosols may burst at temperatures antainers to prevent possible bursting. Aerosols may rosols are bursting, stay clear until bursting is complementable liquids and/or exposed gases if exposed to be by spraying them with water until the fire has been am, CO ₂ , Dry Chemical wear MSHA/NIOSH approved self-contained breathing full protective gear. Keep containers cool until well ire-exposed surfaces and to protect personnel. Fighrol or dilution from entering sewers, drains, drinking efighters must use full bunker gear including NIOSH-athing apparatus to protect against potential hazard in products and oxygen deficiencies. 6. ACCIDENTIAL RELEASE MEASURATION COLUMN SPILL COLU	above 120° F (48°C). Cool be projectile hazards when lete. Containers may rupture the heat of fire. Keep n extinguished. Ing apparatus (pressure- after the fire is out. Use water t fire upwind. Prevent runoff water supply, or any natural rapproved positive pressure self- ous combustion or JRES In must wear appropriate Personal ding gloves and protective eyewear roduct and place into a container for aterial. Sweep up material using no	. Use a non- r later dispos n-sparking		
5.2	Extinguishing Methods: Firefighting Procedures:	Level 2 Aeroso uninvolved con bursting. If ae and release fla containers coo Water Fog, Fog. As in any fire, y demand_ and spray to cool f from fire contravaterway. Fir contained breadecomposition Before cleanin Equipment (PF Small spills We combustible m Do not use wa	5. FIREFIGHTING MEASURES of (NFPA 30B). Aerosols may burst at temperatures antainers to prevent possible bursting. Aerosols may rosols are bursting, stay clear until bursting is complementable liquids and/or exposed gases if exposed to be by spraying them with water until the fire has been am, CO ₂ , Dry Chemical wear MSHA/NIOSH approved self-contained breathing full protective gear. Keep containers cool until well ire-exposed surfaces and to protect personnel. Fighrol or dilution from entering sewers, drains, drinking efighters must use full bunker gear including NIOSH-athing apparatus to protect against potential hazard in products and oxygen deficiencies. 6. ACCIDENTIAL RELEASE MEASURES grany spill or leak, individuals involved in spill cleanures. ear appropriate personal protective equipment inclunaterial such as vermiculite or sand to soak up the protect or a material such as "speedy dry" to soak up the protective equipment inclusted to the protective and the protective equipment inclusted to the protective equipme	above 120° F (48°C). Cool be projectile hazards when lete. Containers may rupture the heat of fire. Keep n extinguished. Ing apparatus (pressure- after the fire is out. Use water t fire upwind. Prevent runoff water supply, or any natural rapproved positive pressure self- ous combustion or JRES In must wear appropriate Personal ding gloves and protective eyewear roduct and place into a container for aterial. Sweep up material using no	. Use a non- r later dispos n-sparking		
5.2	Extinguishing Methods: Firefighting Procedures:	Level 2 Aerosc uninvolved conbursting. If ae and release fla containers coo Water Fog, Foc As in any fire, demand_ and spray to cool f from fire contravaterway. Fire contained bread decomposition. Before cleanin Equipment (PF Small spills We combustible m Do not use wa materials (e.g., container.	5. FIREFIGHTING MEASURES of (NFPA 30B). Aerosols may burst at temperatures antainers to prevent possible bursting. Aerosols may rosols are bursting, stay clear until bursting is complementable liquids and/or exposed gases if exposed to be by spraying them with water until the fire has been am, CO ₂ , Dry Chemical wear MSHA/NIOSH approved self-contained breathing full protective gear. Keep containers cool until well ire-exposed surfaces and to protect personnel. Fighrol or dilution from entering sewers, drains, drinking efighters must use full bunker gear including NIOSH-athing apparatus to protect against potential hazard in products and oxygen deficiencies. 6. ACCIDENTIAL RELEASE MEASURES grany spill or leak, individuals involved in spill cleanures. ear appropriate personal protective equipment inclunaterial such as vermiculite or sand to soak up the protect or a material such as "speedy dry" to soak up the protective equipment inclusted to the protective and the protective equipment inclusted to the protective equipme	above 120° F (48°C). Cool be projectile hazards when lete. Containers may rupture the heat of fire. Keep n extinguished. Ing apparatus (pressure- after the fire is out. Use water t fire upwind. Prevent runoff water supply, or any natural rapproved positive pressure self- ous combustion or JRES In must wear appropriate Personal ding gloves and protective eyewear roduct and place into a container fo aterial. Sweep up material using no plastic container or plastic liner with	. Use a non- r later dispos n-sparking hin another		
5.2	Extinguishing Methods: Firefighting Procedures:	Level 2 Aeroscuninvolved conbursting. If ae and release fla containers cookwater Fog, Fook As in any fire, demand_ and spray to cool f from fire contrained breadecomposition. Before cleanin Equipment (PF Small spills We combustible m Do not use wa materials (e.g. container. Large spills: Ke	5. FIREFIGHTING MEASURES of (NFPA 30B). Aerosols may burst at temperatures antainers to prevent possible bursting. Aerosols may rosols are bursting, stay clear until bursting is completed in the state of the provided provided and/or exposed gases if exposed to only spraying them with water until the fire has been arm, CO ₂ , Dry Chemical wear MSHA/NIOSH approved self-contained breathing full protective gear. Keep containers cool until well ire-exposed surfaces and to protect personnel. Fight rol or dilution from entering sewers, drains, drinking effighters must use full bunker gear including NIOSH-athing apparatus to protect against potential hazard in products and oxygen deficiencies. 6. ACCIDENTIAL RELEASE MEASURE. g any spill or leak, individuals involved in spill cleanure. ear appropriate personal protective equipment incluinaterial such as vermiculite or sand to soak up the protect or a material such as "speedy dry" to soak up material such as shovels, dustpans) and place into a	above 120° F (48°C). Cool be projectile hazards when ete. Containers may rupture the heat of fire. Keep n extinguished. Ing apparatus (pressure- after the fire is out. Use water t fire upwind. Prevent runoff water supply, or any natural rapproved positive pressure self- ous combustion or JRES Ip must wear appropriate Personal ding gloves and protective eyewear roduct and place into a container for aterial. Sweep up material using no plastic container or plastic liner with	. Use a non- r later dispos n-sparking hin another away from s		
5.2	Extinguishing Methods: Firefighting Procedures:	Level 2 Aeroscuninvolved colbursting. If ae and release fla containers cookwater Fog, Fox As in any fire, demand_ and spray to cool ffrom fire contained breadecomposition Before cleanin Equipment (PF Small spills We combustible monot use wa materials (e.g. container. Large spills: Ke release. Isolati	5. FIREFIGHTING MEASURES of (NFPA 30B). Aerosols may burst at temperatures antainers to prevent possible bursting. Aerosols may rosols are bursting, stay clear until bursting is completed in the stay of the sta	above 120° F (48°C). Cool be projectile hazards when ete. Containers may rupture the heat of fire. Keep n extinguished. Ing apparatus (pressure- after the fire is out. Use water t fire upwind. Prevent runoff water supply, or any natural rapproved positive pressure self- ous combustion or JRES Ip must wear appropriate Personal ding gloves and protective eyeweal roduct and place into a container for aterial. Sweep up material using no plastic container or plastic liner with) away from spill. Stay upwind and rsonnel out of area. Stop spill or re	. Use a non- r later dispos n-sparking hin another away from s ease if it car		
5.2	Extinguishing Methods: Firefighting Procedures:	Level 2 Aeroscuninvolved colbursting. If ae and release fla containers cookwater Fog, Fox As in any fire, demand_ and spray to cool ffrom fire contained breadecomposition Before cleanin Equipment (PF Small spills We combustible monot use wa materials (e.g. container. Large spills: Ke release. Isolati	5. FIREFIGHTING MEASURES of (NFPA 30B). Aerosols may burst at temperatures antainers to prevent possible bursting. Aerosols may rosols are bursting, stay clear until bursting is complementable liquids and/or exposed gases if exposed to obly spraying them with water until the fire has been am, CO ₂ , Dry Chemical wear MSHA/NIOSH approved self-contained breathing full protective gear. Keep containers cool until well ire-exposed surfaces and to protect personnel. Figher of or dilution from entering sewers, drains, drinking efighters must use full bunker gear including NIOSH-athing apparatus to protect against potential hazard in products and oxygen deficiencies. 6. ACCIDENTIAL RELEASE MEASURE and propoperate personal protective equipment inclunaterial such as vermiculite or sand to soak up the protect or a material such as "speedy dry" to soak up material such as werniculite or sand to soak up that the protective beginned in the protective of the protect	above 120° F (48°C). Cool be projectile hazards when ete. Containers may rupture the heat of fire. Keep n extinguished. Ing apparatus (pressure- after the fire is out. Use water t fire upwind. Prevent runoff water supply, or any natural rapproved positive pressure self- ous combustion or JRES Ip must wear appropriate Personal ding gloves and protective eyeweal roduct and place into a container for aterial. Sweep up material using no plastic container or plastic liner with) away from spill. Stay upwind and rsonnel out of area. Stop spill or re	. Use a non- r later dispos n-sparking hin another away from s ease if it car		



						AIA SE				
	Prepared to OSHA, AC	CC, ANSI, NOHSC, WHMIS, 2001	/58 & 1272	2/2008/EC S	Standards		SDS Revis	sion: 1. Rev	vision Date: 10/24/	2016
7.1	Work & Hygiene Practices	Do not eat, drink, or smok container(s). When used a contact is possible. Wash	as intende	ed, no add	itional pr	otective equ	ipment is	necessary		_
7.2	Storage and Handling:	Use and store in a cool, dry, well-ventilated location (e.g., local exhaust ventilation, fans) away from heat and direct sunlight. Avoid temperatures above 120 °F. Keep away from incompatible substances. Protect containers from physical damage. To avoid unintentional spraying, keep cap in place when not in use. Storage level 2. Spilled material may present a slipping hazard if left unattended. Clean all spills promptly.								
7.3	Special Precautions:	Spilled material may prese	ent a slipp	ing hazard	l if left un	attended. C	lean all sp	ills prom	otly.	
		8. EXPOSURE (CONTR	ROLS &	PERS	ONAL P	ROTEC	TION		
8.1	Exposure Limits:		AC	GIH		NOHSC	1		OSHA	OTHER
	Ppm (mg/m³)	Chemical Name(s)	TLV	STEL	ES- TWA	ES-STEL	ES-PEAK	PEL	STEL	
		DIMETHYL ETHER	NA	NA	400	760	NF	NA	NA	
8.2	Ventilation & Engineering Controls	General mechanical (e.g., fans) or natural ventilation is sufficient when this product is in use. Use local or general exhaust ventilation to effectively remove and prevent buildup of vapors or mist generated from the handling of this product.								
8.3	Respiratory Protection:	No special respiratory pro- instances where dusts of t protection authorized by 2 Standard Z94.4-93 and ap	his produ 29 CFR §1: plicable st	ct are gen 910.134, a tandards o	erated, a pplicable f Canadia	nd respirato U.S. State ro an Provinces	ry protect egulations , EC memb	ion is nee , or the C per States	ded, use only anadian CAS , or Australia.	
8.4	Eye Protection:	None required under norm handling or using large qua						asses shoi	uld be used wher	
8.5	Hand Protection:	None required under normal conditions of use. However, may cause skin irritation is some sensitive individuals. When handling large quantities (e.g., \geq 1 gallon (3.8 L)), wear rubber, nitrile or impervious plastic gloves.								
8.6	Body Protection:	No apron required when h wash station and deluge s large quantities of this pro	howers sh	nould be a	vailable.	Upon compl	letion of w	ork activi	ties involving	
	•		ICAL O	CLIER						•
		9. PHYS	ICAL 6	k CHEN	/ICAL	PROPER	RTIES			
9.1	Appearance:	9. PHYS Aerosol, misty spray	ICAL 6	k CHEN	/IICAL	PROPE	RTIES			
9.1 9.2	Appearance: Odor:		ICAL &	k CHEN	ЛІСАL	PROPE	RTIES			
9.2 9.3	Odor: Odor Threshold	Aerosol, misty spray Fresh Fruity/Floral NA	ICAL &	k CHEI	ЛІСАL	PROPE	RTIES			
9.2 9.3 9.4	Odor: Odor Threshold pH:	Aerosol, misty spray Fresh Fruity/Floral NA 5.0 – 6.0	ICAL &	k CHEN	ЛІСАL	PROPE	RTIES			
9.2 9.3 9.4	Odor: Odor Threshold pH: Melting/Freezing Point Initial Boiling Point/	Aerosol, misty spray Fresh Fruity/Floral NA 5.0 – 6.0	ICAL &	K CHEN	ΛICAL	PROPE	RTIES			
9.2 9.3 9.4 9.5 9.6	Odor: Odor Threshold pH: Melting/Freezing Point	Aerosol, misty spray Fresh Fruity/Floral NA 5.0 – 6.0 NA			ΛICAL	PROPE	RTIES			
9.2 9.3 9.4 9.5 9.6	Odor: Odor Threshold pH: Melting/Freezing Point Initial Boiling Point/ Boiling Range: Flashpoint:	Aerosol, misty spray Fresh Fruity/Floral NA 5.0 – 6.0 NA NA NA -30 °F (-34 °C) TCC for proposed in the second seco	pellant on	ıly						
9.2 9.3 9.4 9.5 9.6 9.7 9.8	Odor: Odor Threshold pH: Melting/Freezing Point Initial Boiling Point/ Boiling Range: Flashpoint: Upper/Lower Flammability limits Vapor Pressure:	Aerosol, misty spray Fresh Fruity/Floral NA 5.0 – 6.0 NA NA NA -30 °F (-34 °C) TCC for proposed in the second in t	pellant on	ıly				par		
9.2 9.3 9.4 9.5 9.6 9.7 9.8 9.9	Odor: Odor Threshold pH: Melting/Freezing Point Initial Boiling Point/ Boiling Range: Flashpoint: Upper/Lower Flammability limits Vapor Pressure: Vapor Density	Aerosol, misty spray Fresh Fruity/Floral NA 5.0 – 6.0 NA NA -30 °F (-34 °C) TCC for proposed in the second in the	pellant on	ıly				par		
9.2 9.3 9.4 9.5 9.6 9.7 9.8 9.9 9.10 9.11	Odor: Odor Threshold pH: Melting/Freezing Point Initial Boiling Point/ Boiling Range: Flashpoint: Upper/Lower Flammability limits Vapor Pressure: Vapor Density Relative Density:	Aerosol, misty spray Fresh Fruity/Floral NA 5.0 – 6.0 NA NA NA -30 °F (-34 °C) TCC for propose NA @ 20 °C (68° F) – Can pres >1 0.95 – 0.96	pellant on	ıly				par		
9.2 9.3 9.4 9.5 9.6 9.7 9.8 9.9 9.10 9.11 9.12	Odor: Odor Threshold pH: Melting/Freezing Point Initial Boiling Point/ Boiling Range: Flashpoint: Upper/Lower Flammability limits Vapor Pressure: Vapor Density Relative Density: Solubility: Partition Coefficient	Aerosol, misty spray Fresh Fruity/Floral NA 5.0 – 6.0 NA NA -30 °F (-34 °C) TCC for proposed in the second in the	pellant on	ıly				par		
9.2 9.3 9.4 9.5 9.6 9.7 9.8 9.9 9.10 9.11 9.12 9.13	Odor: Odor Threshold pH: Melting/Freezing Point Initial Boiling Point/ Boiling Range: Flashpoint: Upper/Lower Flammability limits Vapor Pressure: Vapor Density Relative Density: Solubility: Partition Coefficient (log Pow): Autoignition	Aerosol, misty spray Fresh Fruity/Floral NA 5.0 – 6.0 NA NA -30 °F (-34 °C) TCC for proposes NA @ 20 °C (68° F) – Can pres >1 0.95 – 0.96 Soluble in water	pellant on	ıly				par		
9.2 9.3 9.4 9.5 9.6 9.7 9.8 9.10 9.11 9.12 9.13	Odor: Odor Threshold pH: Melting/Freezing Point Initial Boiling Point/ Boiling Range: Flashpoint: Upper/Lower Flammability limits Vapor Pressure: Vapor Density Relative Density: Solubility: Partition Coefficient (log Pow):	Aerosol, misty spray Fresh Fruity/Floral NA 5.0 – 6.0 NA NA -30 °F (-34 °C) TCC for prop NA @ 20 °C (68° F) – Can pres >1 0.95 – 0.96 Soluble in water NA	pellant on	ıly				par		
9.2 9.3 9.4 9.5 9.6 9.7 9.8 9.10 9.11 9.12 9.13 9.14	Odor: Odor Threshold pH: Melting/Freezing Point Initial Boiling Point/ Boiling Range: Flashpoint: Upper/Lower Flammability limits Vapor Pressure: Vapor Density Relative Density: Solubility: Partition Coefficient (log Pow): Autoignition Temperature: Decomposition	Aerosol, misty spray Fresh Fruity/Floral NA 5.0 – 6.0 NA NA -30 °F (-34 °C) TCC for prop NA @ 20 °C (68° F) – Can pres >1 0.95 – 0.96 Soluble in water NA NA	pellant on sure not t	ıly				par		



Prepared to OSHA, ACC, ANSI, NOHSC, WHMIS, 2001/58 & 1272/2008/EC Standards SDS Revision: 1. Revision Date: 10/24/2016 10. STABILITY & REACTIVITY 10.1 Stability: Stable at normal temperatures. 10.2 Hazardous Decomposition Oxides of carbon (CO, CO₂) and sulfur (SO₂) Products: 10.3 Hazardous Will not occur. Polymerization: Excessive heat, direct sunlight, flames, heat sources and incompatible substances. 10.4 Conditions to Avoid 10.5 Incompatible Substances Mixture with strong acids, alkalis or oxidizers. 11. TOXICOLOGICAL INFORMATION 11.1 Routes of Entry: Inhalation: YES Absorption: Ingestion: YES 11.2 Toxicity Data: This product was not tested on animals. 11.3 Acute Toxicity: See Section 4.4 See Section 4.5 11.4 Chronic Toxicity: 11.5 Suspected Carcinogen: No. 11.6 Reproductive Toxicity: This product is not reported to cause reproductive toxicity in humans. Mutagenicity: This product is not reported to produce mutagenic effects in humans. Embryo toxicity: This product is not reported to produce embryo toxic effects in humans. Teratogenicity: This product is not report to cause teratogenic effects in humans. Reproductive Toxicity: This product is not report to cause reproductive effects in humans. 11.7 Irritancy of Product: See Section 4.3 11.8 Biological Exposure NA Indices: 11.9 Physician Treat symptomatically. Recommendations: 12. ECOLOGICAL INFORMATION 12.1 Environmental Stability: There is no specific data available for this product. 12.2 Effects on Plants & There is no specific data available for this product. **Animals** 12.3 Effects on Aquatic Life: The product itself has not been tested as a whole. There is no specific data available for this product. 13. DISPOSAL CONSIDERATIONS 13.1 Waste Disposal: Review current local, state and federal laws, codes, statutes and regulations to determine current status and appropriate disposal method for the ingredients listed in Section 2. Any disposal practice must be in compliance with local, state and federal laws and regulations. Contact the appropriate agency for specific information. A licensed facility or waste hauler must provide treatment, transport, storage and disposal of hazardous waste. 13.2 Special Considerations: U.S. EPA Hazardous Waste – Characteristic – Ignitable (D001) 14. TRANSPORTATION INFORMATION UN1950, AEROSOLS, 2.1 (LTD QTY, IP VOL < 1.0 L); or 14.1 49 CFR (GND): CONSUMER COMMODITY, ORM-D (IP VOL ≤ 1.0 L) – until 12/31/2020 14.2 | IATA (AIR) UN1950, AEROSOLS, FLAMMABLE, 2.1 (LTD QTY, IP VOL < 0.5 L); or ID8000, CONSUMER COMMODITY, ORM-D (IP VOL < 0.5 I=L) 14.3 IMDG (OCN): UN1950, AEROSOLS, 2.1 (LTD QTY, IP VOL < 1.0 L) 14.4 TDGR (Canadian GND): UN1950, AEROSOLS, 2.1 (LTD QTY, IP VOL < 1.0 L); or MARK PACKAGE "LIMITED QUANTITY", "LTD QTY", OR "QUANT LTÉE" OR "QUANTITÉ LIMITÉE" 14.5 ADR/RID (EU): UN1950, AEROSOLS, 2.1 (LTD QTY, IP VOL < 1.0 L) 14.6 SCT (MEXICO): UN1950, AEROSOLES, 2.1 (CANTIDAD LIMITADA, IP VOL < 1.0 L) 14.7 ADGR (AUS): UN1950, AEROSOLS, 2.1 (LTD QTY, IP VOL < 1.0 L)



Fax: +1 (574) 295-1709 http://www.kikcorp.com

SAFETY DATA SHEET

Prepared to OSHA, ACC, ANSI, NOHSC, WHMIS, 2001/58 & 1272/2008/EC Standards SDS Revision: 1. Revision Date: 10/24/2016 15. REGULATORY INFORMATION 15.1 SARA Reporting This product does not contain any substance subject to SATA Title III, section 313 reporting requirements. Requirements: 15.2 SARA Threshold There are no specific Threshold Planning Quantities for the components of this product. Planning Quantity: 15.3 TSCA Inventory Status: The components of this product are listed on the TSCA Inventory. 15.4 CERCLA Reportable Quantity (RQ): 15.5 Other Federal This product complies with the appropriate sections of the Food and Drug Administration's 21 CFR Subchapter G. Requirements: (Cosmetics) 15.6 Other Canadian This product has been classified according to the hazard criteria of the CPR and the SDS contains all of Regulations: the information required by the CPR. The components of the product are listed on the DSL/NDSL. None of the components of this product are listed on the Priorities Substance List. WHMIS Class B5 (Flammable Aerosol) 15.7 State Regulatory Dimethyl Ether can be found on the following state criteria lists: MA, MN, PA, WA and NJ Information: No other ingredients of this product, present in a concentration of 1.0% or greater, are listed on any of the following state criteria lists: California Proposition 65 (CA65), Delaware Air Quality Management List (DE), Florida Toxic Substances List (FL), Massachusetts Hazardous Substances List (MA), Michigan Critical Substances List (MI), Minnesota Hazardous Substances List (MN), New Jersey Right-to-Know List (NJ), New York Hazardous Substances List (NY), Pennsylvania Right-to-Know List (PA), Washington Permissible Exposures List (WA), Wisconsin Hazardous Substances 15.8 Other Requirements: The primary components of this product are listed in Annex I of EU Directive 67/548/EEC: Dimethyl Ether: Extremely Flammable (F+). Risk Phrases (R) 12 - Extremely Flammable. Safety Phrases (S): 2-9-16-33 – Keep out of reach of children. Keep container in a well-ventilated area. Keep away from sources of ignition - No smoking. Take precautionary measures against static discharges 16. OTHER INFORMATION WARNING! FLAMMABLE AEROSOL. PRESSURIZED CONTAINER: MAY BURST IF HEATED, HIGHLY FLAMMABLE LIQUID 16.1 Other Information: AND VAPOR. CAUSES EYE IRRITATION. Keep away from heat, hot surfaces, sparks open flames and other ignition sources. No Smoking. Do not spray on an open flame or other ignition source. Do not pierce or burn, even after use. Avoid breathing vapor/spray. Wash thoroughly with soap and water after handling. Use only in a well ventilated area. Wear eye protection. Protect from sunlight. Do not expose to temperature exceeding 50 °C (122 °F). IF INHALED: Remove person to fresh air and keep comfortable for breathing. IF IN EYES: Rinse cautiously with water for several minutes. Remove contact lenses if present and easy to do. Continue rinsing. If eye irritation persists: Get medical advice/attention. KEEP OUT OF REACH OF CHILDREN. 16.2 Terms & Definitions: See last page of this Safety Data Sheet. This Safety Data Sheet is offered pursuant to OSHA's Hazard Communication Standard, 29 CFR §1910.1200. Other 16.3 Disclaimer: government regulations must be reviewed for applicability to this product. To the base of KIK Custom Product's knowledge, the information contained herein is reliable and accurate as of this date; however, accuracy, suitability or complete=ness are not guaranteed and no warranties of any type, either expressed or implied, are provided. The information contained herein relates only to the specific product(s). If this product(s) is combined with other materials, all component properties must be considered. Data may be changed from time to time. Be sure to consult the latest edition. 16.4 Prepared By: **KIK Custom Products** 2730 Middlebury Street KIK
CUSTOM PRODUCTS Elkhart, IN46515 USA Tel: +1 (574) 295-0000



Prepared to OSHA, ACC, ANSI, NOHSC, WHMIS, 2001/58 & 1272/2008/EC Standards SDS Revision: 1. Revision Date: 10/24/2016 **Explosive** Oxidizer Flammable Corrosive Toxic Pressurized Harmful/Irritating Health Hazard Environment Face Shield and Protective **Dust Mask** Apron Eyewear **Full Suit** Scuba **Protective Clothing Safety Glasses Boots** Gloves



Prepared to OSHA, ACC, ANSI, NOHSC, WHMIS, 2001/58 & 1272/2008/EC Standards

Full Face Respirator

Reactive

Irritant / Harmful

Biohazard

Oxidizing

Flammable

Compressed

Toxic

Irritation